

Legend

Infiltration blanket under car park

Soak away crates

Bio-Retention Area

Treepits 2.5*2.5 m wide, 2.35mm deep

NOTE: interconnecting pipes between each treepit not shown

RG

Road Gully

New SW Pipes

New SW Pipes

Pre-Cast Concrete Manhole

Site Boundary

Cover Grades to EN124:
Trafficked areas - D400
Non-trafficked areas - C250
Pedestrian areas - B125

Surface Water Chambers									
Designation	Cover Level	Invert Level	Chamber Type	Cover Grade	Depth m	Diameter mm	Trafficked Y/N		
		In	out						
SW10	41.63	39.48	39.41	MH	D400	2.22	225/300	Y	
SW10.1	41.51		40.17	MH	D400	1.14	225	Y	
SW10.2	41.95	40.51	40.44	MH	D400	1.51	225/150	Y	
SW10.2.1	41.66		40.67	MH	D400	0.99	150	Y	
SW10.3	41.95	40.65	40.58	MH	D400	1.37	225/150	Y	
SW10.3.1	42.13		40.89	MH	D400	1.24	150	Y	
SW11	42.2		39.78	MH	D400	2.42	225	Y	
SW12	42.22	40.65	40.22	MH	D400	2	225/150	Y	
SW12.1	42.35		40.88	MH	D400	1.47	150	Y	
SW12.2	42.66		41.21	MH	D400	1.45	150	Y	
SW13	41.73	39.36		MH	B125	2.37	300	N	
SW14	42.61		41.2	MH	D400	1.41	150	Y	
SW14.1	42.5		40.93	MH	D400	1.59	225/150	Y	
SW15	42.27		40.84	MH	D400	1.43	225	Y	
SW15.1	42.3		40.61	MH	D400	1.69	225	Y	
SW16	42.45		40.81	MH	B125	1.64	225	N	
SW17	42.55		41.63	IC	B125	0.92	225	N	
SW18	42.43		40.9	MH	B125	1.53	225	N	
SW19	42.1		40.87	MH	B125	1.23	225	N	
SW20	42.3		41.4	MH	B125	0.9	225	N	
SW21	42.2		41.28	MH	B125	0.92	225	N	
SW22	42		41.08	MH	B125	0.92	225	N	
SW23	42.3		40.62	MH	B125	1.68	225	N	
SW23.1	41.78		40.34	MH	B125	1.44	225	N	
SW24	42.05		40.93	MH	B125	1.12	225	N	
All levels and inverts to be checked by on-site engineer. Inverts in excess of 1.2m to have restricted access cover of 1500. Any discrepancies to be reported to Engineer.									
All PPVC chambers covers to be bolted down.									

Pipe Specifications:

Surfacewater Pipes:
Unplasticised PVC; Unplasticised PVC pipes and fittings shall comply with the provisions IS EN 1401 2009/2012. Pipes to be application area code "UD", Stiffness Class 8kN/m2
Provision for jetting shall be based on the WRC
Sewer Jetting Code of Practice, June 1997. Pipes to be capable of resisting a maximum jetting pump pressure of 2,600psi (180 Bar) without damage.
(Sewer diameters 150mm up to 450mm, Service Connections of 100mm diameter).

Surfacewater:
Gravity Sewers and Rising Mains shall be designed in accordance with the requirements of BS 9295. As a general guide the, minimum depth of cover from the finished surface to the crown of pipework without protection should be as follows:

- Areas without any possibility of vehicular access - depth not less than 0.5 m;
- Driveways, parking areas and yards with height restrictions to prevent entry by vehicles with a gross vehicle weight in excess of 7.5 tonnes - depth not less than 0.75 m;
- Driveways, parking areas and narrow streets without footways (e.g. mews developments) with access for vehicles with a gross vehicle weight in excess of 7.5 tonnes - depth not less than 0.9 m;
- Agricultural land and public open space - depth not less than 0.9 m;
- Other roadways, highways and parking areas with unrestricted access to vehicles with a gross vehicle weight in excess of 7.5 tonnes - depth not less than 1.2 m.

The depth of cover to pipework can be reduced by the installation of concrete beds and surrounds.

All domestic rainwater gullies to be 'bottle type' gullies, Wavin sewer s/s bottle gully or equivalent.

Site Boundaries Outlined in Red.

Refer to revision sheet for all amendment details

				Client: Wrightwood Developments Ltd.			
				Project Title: New Development at, Ardshanavooley, Killarney			
				Drwg Title: Surfacewater Layout (2)			
B		21.07.26	Layout	JON	MC	Drwn by:	JON
						Date	Sept 2025
A		17.12.25	Layout	JON	MC	chkd by:	M.C
						Date	Sept 2025
Rev		Date	General Revision	Drwn	chkd	Job No:	91-24
Issue for:		Planning				Scale	1:250
						Drwg No:	91-24-1-808
						Ref	
						Sheet	
						Rev	B

ENGINEERING

SURVEYING

ARCHITECTURE

teicniuil-priory

consulting engineers

6 PRIGORY GROVE,
FAIR HILL,
KILLARNEY
CO. KERRY
TEL: 066 6631847
EMAIL: matt@epce.ie